



# Bid Specifications

<b>Date Originated:</b> 02/28/05	<b>Revision:</b> B	<b>Revision Date:</b> 05/08/09	<b>Standards No.</b> 5000046
<b>Subject:</b> SL Series Tank Level Monitor Bid Specifications – 10 LED Master Water Unit			

## 10-LED Master Water Tank Level Monitor

An Innovative Controls SL Series Tank Level Monitor System shall be installed. The system shall include an electronic display module, a pressure transducer-based sender unit, and an extension cable. The display module shall show the volume of water in the tank using 10 superbright easy-to-see LEDs. Tank level indication is enhanced by the use of green LEDs at the full and near-full levels, amber LEDs between  $\frac{3}{4}$  and  $\frac{1}{4}$  tank levels, and red LEDs at the near-empty and empty levels. A wide-angle diffusion lens in front of the LEDs creates a 180° viewing angle. The electronic display module shall be waterproof and shock resistant being encapsulated in a urethane-based potting compound. The potted display module shall be mounted to a chrome plated panel-mount bezel with a durable easy-to-read polycarbonate insert featuring blue graphics and a water icon.

All programming functions shall be accessed and performed from the front of the display module. The programming includes manual or self-calibration and networking capabilities to connect remote slave displays. Low tank level warnings shall include flashing red LEDs starting below the  $\frac{1}{4}$  level, down-chasing LEDs when the tank is almost empty, and an output for an audible alarm.

The display module shall receive an input signal from a pressure transducer. This stainless steel sender unit shall be installed on the outside of the water tank near the bottom. All wiring, cables and connectors shall be waterproof without the need for sealing grease.

**Location of water tank level monitor shall be:**