



Bid Specifications

Date Originated: 02/28/05	Revision: B	Revision Date: 05/08/09	Standards No. 5000058
Subject: SL Series Tank Level Monitor Bid Specifications – 14 LED Master Foam B Unit			

14-LED Master Class B Foam Tank Level Monitor

An Innovative Controls SL Series Tank Level Monitor System shall be installed. The system shall include an electronic display module, a pressure transducer-based sender unit, and an extension cable. The display module shall show the volume of Class B foam in the tank using 14 superbright easy-to-see LEDs. Tank level indication is enhanced by the use of green LEDs at the full level, amber LEDs at the $\frac{3}{4}$, $\frac{1}{2}$ and $\frac{1}{4}$ tank levels, and red LEDs at the empty level. Wide-angle diffusion lenses in front of the LEDs create a 180° viewing angle. The electronic display module shall be waterproof and shock resistant being encapsulated in a urethane-based potting compound. The potted display module shall be mounted to a chrome plated panel-mount bezel with a durable easy-to-read polycarbonate insert featuring red graphics and a foam icon.

All programming functions shall be accessed and performed from the front of the display module. The programming includes manual or self-calibration and networking capabilities to connect remote slave displays. Low tank level warnings shall include flashing red LEDs starting below the $\frac{1}{4}$ level, down-chasing LEDs when the tank is almost empty, and an output for an audible alarm.

The display module shall receive an input signal from a pressure transducer. This stainless steel sender unit shall be installed on the outside of the foam tank near the bottom. All wiring, cables and connectors shall be waterproof without the need for sealing grease.

Location of Class B foam tank level monitor shall be: